



NOTES:

1. VENT PIPE SHALL BE 4" SCHEDULE 40 STEEL PIPE.
2. INSIDE OF VENT PIPE SHALL HAVE A 3/32 INCH COAL TAR LINING ACCORDING TO AWWA C 203.
3. OUTSIDE OF VENT PIPE SHALL BE SAND BLASTED TO COMMERCIAL STANDARDS AND HAVE ONE COAT OF ZINC CHROMATE PRIMER APPLIED ACCORDING TO FEDERAL SPECIFICATION TT-86A OR LATEST REVISION. THEN VENT PIPE SHALL HAVE TWO EVENLY APPLIED COATS OF RUST INHIBITING ENAMEL PAINT, EITHER KOPPERS GLAMORTEX NO.501 ENAMEL (OLIVE GREEN), SOUTHERN COATINGS RUSTALOY NO.0537 ENAMEL (GARDEN GREEN), OR APPROVED EQUAL.
4. MANHOLE STEPS TO BE VERTICALLY IN LINE WITH "INVERT OUT" FOR PIPE 18" AND LESS OVER 18" TO BE LOCATED IN LINE WITH BENCH.

STANDARD DETAIL	
CITY OF CAYCE	
LATERAL EXTENSION OF MANHOLE VENT DETAIL	
APPROVED:	# CAYCE-3B