



NOTES:

1. HYDRANT DRAINS SHALL NOT BE CONNECTED TO OR LOCATED WITHIN 10 FEET OF SEWER SYSTEMS.
2. DO NOT BLOCK HYDRANT WEEP HOLES WITH THRUST BLOCKING.

STANDARD HYDRANT DETAIL  
NOT TO SCALE

STANDARD DETAIL	
CITY OF CAYCE	
HYDRANT DETAIL	
APPROVED:	# DWCAyce-1